



# CITY OF ENCINITAS

## Nonresidential/High-Rise Residential Solar Photovoltaic Regulations



Encinitas Municipal Code Section 23.12.080.B and C

### What projects are affected?

Ordinance 2024-04, adopted by City Council on June 12, 2024, affects all **existing** nonresidential, high-rise multifamily residential, and hotel/motel buildings **additions that increase total roof area by at least 1,000 sq. ft. or alterations with a permit value of at least \$1,000,000 that affect at least 75% of gross floor area.**

### What are the requirements?

Required solar photovoltaic (PV) equipment shall be sized according to ONE of the following methods:

1) Based on Gross Floor Area of Building:

**Gross floor area  $\geq$  10,000 sq. ft.:** at least 15 kilowatts direct current (kWdc) per 10,000 sq. ft. of gross floor area.  
Example: PV system size = 15 kWdc X (Gross Area / 10,000 sq. ft.) where resulting product shall be rounded to nearest whole number. For example, an applicant with a 126,800 sq. ft. building shall install a minimum 191 kWdc PV system; or

**Gross floor area < 10,000 sq. ft.:** a minimum size of 5 kWdc.

Example:

Note: Applicants are encouraged to right-size PV systems based on buildings' electrical demand to improve system's cost effectiveness. Applicants should also ensure that the PV system meets electrical corporation net energy metering (NEM) requirements, if applicable.

2) Based on New Construction Energy Code:

Comply with California Title 24, Part 6 Energy Code Section 140.10(a) or 170.2(g), which otherwise applies to new construction.

$$kW_{PVdc} = (CFA \times A)/1000$$

Where:

$kW_{PVdc}$  = Size of the PV system in kW

CFA = Conditioned floor area in square feet

A = PV capacity factor specified in [Table 140.10-A](#)/ [Table 170.2-U](#) for the [building](#) type



# CITY OF ENCINITAS

## Nonresidential/High-Rise Residential Solar Photovoltaic Regulations



Encinitas Municipal Code Section 23.12.080.B and C

### Are there any exceptions?

- 1) The requirement may be waived or reduced:
  - a. On a case-by-case basis, where it is determined that there are sufficient practical challenges that make compliance infeasible, including: building site location; limited rooftop availability; shading from nearby structures, topography, or vegetation; or structural load limitations.
  - b. By the maximum extent necessary, if it is determined that this requirement through the use of alternative on-site renewable generation, such as wind energy systems.
- 2) Applicants may comply:
  - a. By voluntarily installing ground mounted PV; or
  - b. By enrolling in a local utility provider's renewable energy portfolio program that provides the greatest available percentage of electrical power from renewable energy sources.
- 3) Greenhouse structures used for commercial cultivation, educational purposes, or the conservancy of plants or animals are exempt from this requirement.
- 4) Aesthetic, exterior only façade alterations may be excluded from the permit valuation calculation.

### Where can I obtain additional information?

For more information, contact the Development Services Department at [planning@encinitasca.gov](mailto:planning@encinitasca.gov) or call 760-633-2710. You can also visit the department's public counter to learn more.

City of Encinitas Development Services Department  
505 South Vulcan Avenue, Encinitas CA 92024  
(760) 633-2710 • [planning@encinitasca.gov](mailto:planning@encinitasca.gov) • [www.encinitasca.gov](http://www.encinitasca.gov)